



Environmental and Laboratory Services

Dover Location:

90 1/2 West Blackwell St., Dover, NJ 07801
Phone: (973) 989-0010, Fax (973) 989-0156

Marlboro Location:

8A Railroad Ave, Marlboro, NJ 07746
Phone: (732) 308-3500, Fax (732) 308-3503

Date: March 17, 2022
Client: Shepard Preparatory High School
Address: 8 Columba Street
Morristown, NJ 07960

Analytical Results

PWSID#:

Project Location:

| Sample Matrix: | Drinking Water | Lab Sample Number: 220303005-001 | | | | | | | |
|-------------------|----------------|----------------------------------|-------|-------------|---------------|---------------|---------|-----------------|-----------------|
| Sample Location: | Field Blank | Customer Sample Number: | | | | | | | |
| Sampled By: | J. Walburn | | | | | | | | |
| Sample Date/Time: | 3/4/2022 7:36 | | | | | | | | |
| Parameters | Method | Results | Units | NJDEP Limit | Date Analyzed | Time Analyzed | Analyst | Reporting Limit | Dilution Factor |
| Lead-1st Draw | SM3113B | < 2.00 | µg/L | 15 | 3/10/2022 | 12:05 | JGW | 2 | 1 |

| Sample Matrix: | Drinking Water | Lab Sample Number: 220303005-002 | | | | | | | |
|-------------------|------------------|----------------------------------|-------|-------------|---------------|---------------|---------|-----------------|-----------------|
| Sample Location: | Kitchen Sink - L | Customer Sample Number: | | | | | | | |
| Sampled By: | J. Walburn | | | | | | | | |
| Sample Date/Time: | 3/4/2022 7:37 | | | | | | | | |
| Parameters | Method | Results | Units | NJDEP Limit | Date Analyzed | Time Analyzed | Analyst | Reporting Limit | Dilution Factor |
| Lead-1st Draw | SM3113B | 4.91 | µg/L | 15 | 3/10/2022 | 12:27 | JGW | 2 | 1 |

Shepard Preparatory High School

| Sample Matrix: Drinking Water | | Lab Sample Number: 220303005-003 | | | | | | | |
|-----------------------------------|---------|----------------------------------|-------|-------------|---------------|---------------|---------|-----------------|-----------------|
| Sample Location: Kitchen Sink - R | | Customer Sample Number: | | | | | | | |
| Sampled By: J. Walburn | | | | | | | | | |
| Sample Date/Time: 3/4/2022 7:39 | | | | | | | | | |
| Parameters | Method | Results | Units | NJDEP Limit | Date Analyzed | Time Analyzed | Analyst | Reporting Limit | Dilution Factor |
| Lead-1st Draw | SM3113B | 5.60 | µg/L | 15 | 3/10/2022 | 12:33 | JGW | 2 | 1 |

| Sample Matrix: Drinking Water | | Lab Sample Number: 220303005-004 | | | | | | | |
|-------------------------------------|---------|----------------------------------|-------|-------------|---------------|---------------|---------|-----------------|-----------------|
| Sample Location: Gym Water Fountain | | Customer Sample Number: | | | | | | | |
| Sampled By: J. Walburn | | | | | | | | | |
| Sample Date/Time: 3/4/2022 7:40 | | | | | | | | | |
| Parameters | Method | Results | Units | NJDEP Limit | Date Analyzed | Time Analyzed | Analyst | Reporting Limit | Dilution Factor |
| Lead-1st Draw | SM3113B | < 2.00 | µg/L | 15 | 3/10/2022 | 12:38 | JGW | 2 | 1 |

| Sample Matrix: Drinking Water | | Lab Sample Number: 220303005-005 | | | | | | | |
|----------------------------------|---------|----------------------------------|-------|-------------|---------------|---------------|---------|-----------------|-----------------|
| Sample Location: Teachers Lounge | | Customer Sample Number: | | | | | | | |
| Sampled By: J. Walburn | | | | | | | | | |
| Sample Date/Time: 3/4/2022 7:44 | | | | | | | | | |
| Parameters | Method | Results | Units | NJDEP Limit | Date Analyzed | Time Analyzed | Analyst | Reporting Limit | Dilution Factor |
| Lead-1st Draw | SM3113B | < 2.00 | µg/L | 15 | 3/10/2022 | 12:44 | JGW | 2 | 1 |

| Sample Matrix: Drinking Water | | Lab Sample Number: 220303005-006 | | | | | | | |
|----------------------------------|---------|----------------------------------|-------|-------------|---------------|---------------|---------|-----------------|-----------------|
| Sample Location: Nurses's Office | | Customer Sample Number: | | | | | | | |
| Sampled By: J. Walburn | | | | | | | | | |
| Sample Date/Time: 3/4/2022 7:48 | | | | | | | | | |
| Parameters | Method | Results | Units | NJDEP Limit | Date Analyzed | Time Analyzed | Analyst | Reporting Limit | Dilution Factor |
| Lead-1st Draw | SM3113B | < 2.00 | µg/L | 15 | 3/10/2022 | 12:49 | JGW | 2 | 1 |

| Sample Matrix: Drinking Water | | Lab Sample Number: 220303005-007 | | | | | | | |
|----------------------------------|---------|----------------------------------|-------|-------------|---------------|---------------|---------|-----------------|-----------------|
| Sample Location: Room 7 Fountain | | Customer Sample Number: | | | | | | | |
| Sampled By: J. Walburn | | | | | | | | | |
| Sample Date/Time: 3/4/2022 7:54 | | | | | | | | | |
| Parameters | Method | Results | Units | NJDEP Limit | Date Analyzed | Time Analyzed | Analyst | Reporting Limit | Dilution Factor |
| Lead-1st Draw | SM3113B | < 2.00 | µg/L | 15 | 3/10/2022 | 12:55 | JGW | 2 | 1 |

| Sample Matrix: Drinking Water | | Lab Sample Number: 220303005-008 | | | | | | | |
|----------------------------------|---------|----------------------------------|-------|-------------|---------------|---------------|---------|-----------------|-----------------|
| Sample Location: Room 2 Fountain | | Customer Sample Number: | | | | | | | |
| Sampled By: J. Walburn | | | | | | | | | |
| Sample Date/Time: 3/4/2022 7:56 | | | | | | | | | |
| Parameters | Method | Results | Units | NJDEP Limit | Date Analyzed | Time Analyzed | Analyst | Reporting Limit | Dilution Factor |
| Lead-1st Draw | SM3113B | < 2.00 | µg/L | 15 | 3/10/2022 | 13:00 | JGW | 2 | 1 |

NJ Lab ID# 14013 (Dover)
 NJ Lab ID# 13033 (Marlboro)

NJDEP Limit for free and/or total chlorine does not apply to non-chlorinated samples.
 Any method followed by an asterisk (*) was analyzed by the Agra-Marlboro laboratory.
 All other methods, unless otherwise specified, were analyzed by the Agra-Dover laboratory.

I certify that these samples were analyzed in accordance with procedures approved by the New Jersey Department of Environmental Protection.

Susan VanVeen
 Susan VanVeen, Laboratory Manager

March 17, 2022



CHAIN OF CUSTODY / SAMPLE ANALYSIS REQUEST

220303005

Customer Name: Shepard Preparatory High School
 Location: 8 Columba Street
 Address: Morrirstown, NJ, 07960
 Customer Contact: Florian Dilizia
 Phone: Work/Cell 973-247-1375 / 973-247-1375

Report to: Annmarie Scorzo
 ascorzo@windsorschools.com

Agra Environmental Services
 90 1/2 West Blackwell Street
 Dover, NJ 07801
 Phone: (973) 989-0010
 Fax: (973) 989-0156

Matrix Abbreviations: DW - Drinking water, GW - Ground Water, RAW-GW - DW RAW GW, WW/NPW - Wastewater, SL - Sludge, P - Pool, L - Lake

| Sample ID | Location | Date | Time | Grab | Comp | Matrix | # of Bottles | Preservative | ANALYSIS REQUESTED | pH / Temp | Field Analysis |
|---------------|--------------------|--------|------|------|------|--------|--------------|--------------|--------------------|-----------|------------------------------------|
| 220303005-001 | Field Blank | 3-4-22 | 0736 | X | | DW | 1 | HNO3 | Lead-1st Draw | | Cl ₂ or PO ₄ |
| 220303005-002 | Kitchen Sink - L | | 0737 | X | | DW | 1 | HNO3 | Lead-1st Draw | | |
| 220303005-003 | Kitchen Sink - R | | 0739 | X | | DW | 1 | HNO3 | Lead-1st Draw | | |
| 220303005-004 | Gym Water Fountain | | 0740 | X | | DW | 1 | HNO3 | Lead-1st Draw | | |
| 220303005-005 | Teacher's lounge | | 0744 | X | | DW | 1 | HNO3 | Lead-1st Draw | | |
| 220303005-006 | Nurses office | | 0749 | X | | DW | 1 | HNO3 | Lead-1st Draw | | |
| 220303005-007 | Room 7 Fountain | | 0754 | X | | DW | 1 | HNO3 | Lead-1st Draw | | |
| 220303005-008 | Room 2 Fountain | | 0756 | X | | DW | 1 | HNO3 | Lead-1st Draw | | |

Project: Lead

Sampled By (name/company): *Annmarie Scorzo*

Are these samples for compliance? (circle one): Yes or **No**

NJDEP Laboratory Certification (Dover, NJ) #14013
 NJDEP Laboratory Certification (Marlboro, NJ) #13033

Reporting Requirements (Check Box):
 Standard NJ Reduced Other (Specify)

Indicate laboratory location where analysis request was performed:
 Cooler Temperature Upon Receipt at lab: *1.50c*

Sample Custody Exchanges (Please use full legal signature)

| Relinquished By: | Date: | Time: | Received By: | Date: | Time: |
|--------------------|--------|-------|--------------------|--------|-------|
| <i>[Signature]</i> | 3/4/22 | 1255 | <i>[Signature]</i> | 3/4/22 | 1307 |
| | | | | | |
| | | | | | |
| | | | | | |

Comments:
 1 Field Blank
 2 kitchen
 1 teacher's lounge
 1 nurse
 3 water fountains
 Date Faxed _____
 Invoice Number _____

Is sample known to be hazardous? (circle one)
 Yes or No