



**Environmental and Laboratory Services**

**Dover Location:**  
90 1/2 West Blackwell St., Dover, NJ 07801  
Phone: (973) 989-0010, Fax (973) 989-0156

**Marlboro Location:**  
8A Railroad Ave, Marlboro, NJ 07746  
Phone: (732) 308-3500, Fax (732) 308-3503

Date: March 28, 2022  
Client: Shepard School, Inc  
Address: 2 Miller Road  
Kinnelon, NJ 07405

## Analytical Results

PWSID#:  
Project Location:

Sample Matrix: Drinking Water      Lab Sample Number: 220315021-001  
Sample Location: Foyer Fountain      Customer Sample Number:  
Sampled By: J. Walburn  
Sample Date/Time: 3/16/2022 7:30

Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor
Lead-1st Draw	SM3113B	2.11	µg/L	15	3/22/2022	14:00	JGW	2	1

Sample Matrix: Drinking Water      Lab Sample Number: 220315021-002  
Sample Location: Foyer Fountain      Customer Sample Number:  
Sampled By: J. Walburn  
Sample Date/Time: 3/16/2022 7:35

Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor
Lead	SM3113B	3.19	µg/L	5	3/22/2022	14:06	JGW	2	1

Sample Matrix: Drinking Water		Lab Sample Number: 220315021-003							
Sample Location: Hallway Fountain		Customer Sample Number:							
Sampled By: J. Walburn									
Sample Date/Time: 3/16/2022 7:28									
Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor
Lead-1st Draw	SM3113B	4.76	µg/L	15	3/22/2022	14:55	JGW	2	1

Sample Matrix: Drinking Water		Lab Sample Number: 220315021-004							
Sample Location: Hallway Fountain		Customer Sample Number:							
Sampled By: J. Walburn									
Sample Date/Time: 3/16/2022 7:50									
Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor
Lead	SM3113B	2.95	µg/L	5	3/22/2022	15:01	JGW	2	1

NJ Lab ID# 14013 (Dover)  
 NJ Lab ID# 13033 (Marlboro)

NJDEP Limit for free and/or total chlorine does not apply to non-chlorinated samples.  
 Any method followed by an asterisk (\*) was analyzed by the Agra-Marlboro laboratory.  
 All other methods, unless otherwise specified, were analyzed by the Agra-Dover laboratory.

I certify that these samples were analyzed in accordance with procedures approved by the New Jersey Department of Environmental Protection.

Susan VanVeen  
 Susan VanVeen, Laboratory Manager

March 28, 2022



# CHAIN OF CUSTODY / SAMPLE ANALYSIS REQUEST

220315021  
220315021

Customer Name: Shepard School, Inc  
 Location: ascorzo@windsorschools.com  
 Address: 2 Miller Road  
 Kinnelon, NJ, 07405  
 Customer Contact: Katie Dulfer  
 Phone: Work/Cell 973-850-6130 / 973-850-6130

Report to: Annmarie Scorzio  
 ascorzo@windsorschools.com

Agra Environmental Services  
 90 1/2 West Blackwell Street  
 Dover, NJ 07801  
 Phone: (973) 989-0010  
 Fax: (973) 989-0156

Asc./HCl Vials #  
 HCl Vials #  
 Na<sub>2</sub>S<sub>2</sub>O<sub>8</sub> #  
 HNO<sub>3</sub> #  
 H<sub>2</sub>SO<sub>4</sub> #  
 NaOH #  
 unpreserved other #

Matrix Abbreviations:	DW - Drinking water	GW - Ground Water	RAW - RAW GW	WW/NPW - Wastewater	SL - Sludge	P - Pool	L - Lake	Page 1 of 1
Project: Lead	Collection	PWSID#	Comp	Matrix	# of Bottles	Preservative	ANALYSIS REQUESTED	Field Analysis
220315021-001	Foyer Fountain		X	DW	1	HNO3	Lead-1st Draw	pH / Temp
220315021-002	Foyer Fountain		X	DW	1	HNO3	Lead	Cl <sub>2</sub> or PO <sub>4</sub>
220315021-003	Hallway Fountain		X	DW	1	HNO3	Lead-1st Draw	
220315021-004	Hallway Fountain		X	DW	1	HNO3	Lead	

Sampled By (name/company): *Stewart/Agra* Are these samples for compliance? (circle one): Yes or **No**

NJDEP Laboratory Certification (Dover, NJ) #14013  
 NJDEP Laboratory Certification (Marlboro, NJ) #13033

Reporting Requirements (Check Box):  
 Standard  NJ Reduced  Other (Specify)

Indicate laboratory location where analysis request was performed  
 Cooler Temperature Upon Receipt at lab: *1.6°C*

**Sample Custody Exchanges (Please use full legal signature)**

Relinquished By: *[Signature]* Received By: *[Signature]*  
 Date: 3-16-22 Time: 1351 Date: 3/16/22 Time: 1416

Relinquished By: \_\_\_\_\_ Received By: \_\_\_\_\_  
 Date: \_\_\_\_\_ Date: \_\_\_\_\_

Relinquished By: \_\_\_\_\_ Received By: \_\_\_\_\_  
 Date: \_\_\_\_\_ Date: \_\_\_\_\_

Comments: First draw and flush samples for both fountains.

Is sample known to be hazardous? (circle one) Yes or No



**Environmental and Laboratory Services**

**Dover Location:**

90 1/2 West Blackwell St., Dover, NJ 07801  
Phone: (973) 989-0010, Fax (973) 989-0156

**Marlboro Location:**

8A Railroad Ave, Marlboro, NJ 07746  
Phone: (732) 308-3500, Fax (732) 308-3503

Date: March 08, 2022  
Client: Shepard School, Inc  
Address: 2 Miller Road  
Kinnelon, NJ 07405

## Analytical Results

PWSID#:

Project Location:

Sample Matrix:	Drinking Water	Lab Sample Number: 220302033-001							
Sample Location:	Field Blank	Customer Sample Number:							
Sampled By:	J. Walburn								
Sample Date/Time:	3/3/2022 7:32								
Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor
Lead-1st Draw	SM3113B	< 2.00	µg/L	15	3/7/2022	11:31	JGW	2	1

Sample Matrix:	Drinking Water	Lab Sample Number: 220302033-002							
Sample Location:	Nurse's Office	Customer Sample Number:							
Sampled By:	J. Walburn								
Sample Date/Time:	3/3/2022 7:33								
Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor
Lead-1st Draw	SM3113B	< 2.00	µg/L	15	3/7/2022	11:37	JGW	2	1

Sample Matrix: Drinking Water		Lab Sample Number: 220302033-003							
Sample Location: Hallway Fountain		Customer Sample Number:							
Sampled By: J. Walburn									
Sample Date/Time: 3/3/2022 7:34									
Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor
Lead-1st Draw	SM3113B	16.4 **	µg/L	15	3/7/2022	11:42	JGW	2	1

Sample Matrix: Drinking Water		Lab Sample Number: 220302033-004							
Sample Location: Teacher's Lounge		Customer Sample Number:							
Sampled By: J. Walburn									
Sample Date/Time: 3/3/2022 7:35									
Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor
Lead-1st Draw	SM3113B	< 2.00	µg/L	15	3/7/2022	11:48	JGW	2	1

Sample Matrix: Drinking Water		Lab Sample Number: 220302033-005							
Sample Location: Foyer Fountain		Customer Sample Number:							
Sampled By: J. Walburn									
Sample Date/Time: 3/3/2022 7:36									
Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor
Lead-1st Draw	SM3113B	8.20	µg/L	15	3/7/2022	11:53	JGW	2	1

Sample Matrix: Drinking Water		Lab Sample Number: 220302033-006							
Sample Location: Kitchen Sink - R		Customer Sample Number:							
Sampled By: J. Walburn									
Sample Date/Time: 3/3/2022 7:38									
Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor
Lead-1st Draw	SM3113B	10.3	µg/L	15	3/7/2022	11:59	JGW	2	1

Shepard School, Inc

Sample Matrix:	Drinking Water	Lab Sample Number: 220302033-007							
Sample Location:	Kitchen Sink - Middle	Customer Sample Number:							
Sampled By:	J. Walburn								
Sample Date/Time:	3/3/2022 7:39								
Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor
Lead-1st Draw	SM3113B	3.17	µg/L	15	3/7/2022	12:21	JGW	2	1

Sample Matrix:	Drinking Water	Lab Sample Number: 220302033-008							
Sample Location:	Kitchen Sink - L	Customer Sample Number:							
Sampled By:	J. Walburn								
Sample Date/Time:	3/3/2022 7:40								
Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor
Lead-1st Draw	SM3113B	3.24	µg/L	15	3/7/2022	12:27	JGW	2	1

NJ Lab ID# 14013 (Dover)  
NJ Lab ID# 13033 (Marlboro)

\*\* Result does not meet NJDEP Limits.  
NJDEP Limit for free and/or total chlorine does not apply to non-chlorinated samples.  
Any method followed by an asterisk (\*) was analyzed by the Agra-Marlboro laboratory.  
All other methods, unless otherwise specified, were analyzed by the Agra-Dover laboratory.

I certify that these samples were analyzed in accordance with procedures approved by the New Jersey Department of Environmental Protection.

Susan VanVeen  
Susan VanVeen, Laboratory Manager

March 08, 2022



# CHAIN OF CUSTODY / SAMPLE ANALYSIS REQUEST

220302033

Customer Name: Shepard School, Inc  
 Location: 2 Miller Road  
 Address: Kinnelon, NJ, 07405  
 Customer Contact: Katie Dulfer

Report to: Annmarie Scorzo  
 ascorzo@windsorschools.com

Agra Environmental Services  
 90 1/2 West Blackwell Street  
 Dover, NJ 07801  
 Phone: (973) 989-0010  
 Fax: (973) 989-0156

- # Asc / HCl Vials pH
- # HCl Vials pH
- # Na<sub>2</sub>S<sub>2</sub>O<sub>8</sub> Cl<sub>2</sub>
- # HNO<sub>3</sub> pH
- # H<sub>2</sub>SO<sub>4</sub> pH
- # NaOH pH
- # unpreserved
- # other
- # other

Matrix Abbreviations: DW - Drinking water GW - Ground Water RAW - Raw Water WW/NPW - Wastewater SL - Sludge P - Pool L - Lake

Sample ID	Location	Date	Time	Collection	PWSID#	Grab	Comp	Matrix	# of Bottles	Preservative	ANALYSIS REQUESTED	Field Analysis
220302033-001	Field Blank	3-07-22	0730	X			DW	DW	1	HINDS	Lead-1st Draw	Cl <sub>2</sub>
220302033-002	Nurse's lounge		0733	X			DW	DW	1	HINDS	Lead-1st Draw	or
220302033-003	Hallway Countertop		0734	X			DW	DW	1	HINDS	Lead-1st Draw	PO <sub>4</sub>
220302033-004	Teacher's lounge		0735	X			DW	DW	1	HINDS	Lead-1st Draw	
220302033-005	Foyer Fountain		0736	X			DW	DW	1	HINDS	Lead-1st Draw	
220302033-006	Kitchen Sink-R		0738	X			DW	DW	1	HINDS	Lead-1st Draw	
220302033-007	Kitchen Sink-Middle		0739	X			DW	DW	1	HINDS	Lead-1st Draw	
220302033-008	Kitchen Sink-L		0740	X			DW	DW	1	HINDS	Lead-1st Draw	


Project: Lead for laboratory use only

Page 1 of 1

Sampled By (name/company): J J Walburn/Agra

Are these samples for compliance? (circle one): Yes or No  
 NJDEP Laboratory Certification (Dover, NJ) #14013  
 NJDEP Laboratory Certification (Marlboro, NJ) #13033

Indicate laboratory location where analysis request was performed



Cooler Temperature Upon Receipt at lab  
 1.6°

Reporting Requirements (Check Box): Standard

### Sample Custody Exchanges (Please use full legal signature)

Relinquished By:	Date:	Time:	Received By:	Date:	Time:	Comments:
[Signature]	3-07-22	1358	[Signature]	3-7-22	1420	3 kitchen 1 teacher's lounge 1 nurse 2 water fountains
Relinquished By:	Date:	Time:	Received By:	Date:	Time:	Date Faxed
Relinquished By:	Date:	Time:	Received By:	Date:	Time:	Invoice Number
Relinquished By:	Date:	Time:	Received By:	Date:	Time:	Is sample known to be hazardous? (circle one)